

2023 07 26

2023 07 26

			2023 7 26													
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
	mg/L	mg/L		NTU			pH	mg/L	mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
2307261( )	-	-	25	17.0	0		7.11	2.56	-	0.063	/	/	/	-	0.115	0.016
2307262( )	0.18	0.30	5	0.136	0		7.14	1.20	0.02	-	/	/	-	/	0.02	0.011
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2	15	1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2006)					1 2										