

2023 09 20

2023 09 20

				2023 9 20												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
				NTU			pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
230920YS01	-	-	20	26.0			7.96	3.28	-	0.45	/	/	/	/	0.10	0.03
230920CC01	0.24	0.47	<5	0.32			7.23	1.12	0.07	-	/	/	/	/	0.10	0.03
GB3838-2002							6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1			6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2023)					1. 2.										