

2023 09 17

2023 09 17

				2023 9 17													
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
				NTU			°C	pH		mg/L	mg/L	CFU/ml	MPN/100ml	MPN/L	MPN/100ml	mg/L	mg/L
230917YS01	-	-	25	32.0			26.3	7.21	4.00	-	0.53	/	/	/	/	/	/
230917CC01	0.36	0.34	<5	0.14			26.3	7.18	1.76	0.18	-	/	/	/	/	/	/
GB3838-2002								6.9	6		1.0			10000		0.3	0.1
GB/T5749-2022	0.1 0.8	0.3 2		1				6.5 8.5	3	0.5		100				0.3	0.1
	(GB5750-2023)					1. 2.											